Gravity 25% Reduction
FOR WASTEWATER TREATMENT

Owner:	IREDELL GROUP
Address:	109-C Williamson Road Mooresville, NC 28115
Phone:	704-663-4050
County:	Iredell
Location:	Walden Ridge Subdivision Lot #60
Source of Wastewater Flow:	4 Bedroom Single Family Residence
Estimated Daily Wastewater Production:	480 gpd
System Flow:	NA

Design Specifications

Drainfield Size:	480
Loading Rate:	0.25
Depth of Gravel in Trench:	NA (25% reduction)
Gravel Size:	NA (25% reduction)
Trench Depth:	36 in.
Trench Width:	36 in.
Septic Tank Size:	1000
Pump Tank Size:	NA
Estimated Supply Line Length:	20
Supply Line Diameter:	3 in. SCH 40 PVC
Supply Line Volume:	3.48
Dosing Volume:	NA
Supply Manifold:	DROP BOX
Supply Manifold Length:	NA
Supply Manifold Volume:	N/A
Recommended Float Controls:	NA
Recommended Control Panel:	NA
Pressure Head:	NA
Friction Head:	NA
Elevation Head:	NA
Total Dynamic Head:	NA
Threaded Union:	NA
Gate Valves:	NA NA
Check Valves:	NA
Anti-Siphon Hole:	NA
Additional Comments:	Soil suitability was performed by Rollans Soil & Environmental Services.