10 ~~

REDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134623 PIN# 4676638645 DATE April 19,06

OWNER OR APPLICANT Redell Group LLC PHONE: Business 704 344-5944 Home

ADDRESS 109-C Williamson Rd Mooresville N.C. 28117

LOCATION Linwood Rd. (S) TL Teeter Rd. TR Walden Dr. on left near end

SUBDIVISION Walden Ridge BLOCK / SECTION LOT 58 LOT AREA 1.48 AC SITE CLASS. PS DESIGN FLOW 480gpd L.T.A.R. .025

Septic Tank: 1000 Gallons; STB 1@2 Date 9/8/06

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1440 Linear Feet 480

No Lines 4 3 Trench Width 36" Max Trench Bottom Depth 28"

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Gravity 25% Reduction

Repair System Description: PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

Gravel Depth NA ☒ Gravity ☐ Pressure ☐ Slab ~~☒ Crawl Space~~ ☒ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons

☐ Business No. Employees

☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions:

INSTALLER NOTE MAXIMUM trench bottom depth!

Comments:/Conditions:

3@160'x3' House moved toward road to allow for plumbing to ST

Tank 75' from (L) Rear Corner

INITIAL SITE SKETCH

SEE PLAN from Rollins Soil & Env. Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 4-24-06

Improvement Permit by: date 4-19-06

Authorization to Construct by: Judy Medlin date 4-11-06

Installed by: A-1 Backhoe

Operation Permit by: Wesley Sparks R.S. date 3/9/07

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK