IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 140 393 PIN # 4676711544 DATE 9-17-09

OWNER or APPLICANT Mid-Atlantic PHONE: Business 828 478-2761 Home:

OWNER or APPLICANT ADDRESS P.O. Box 3792 Mooresville, NC 28117

LOCATION / DIRECTIONS Main St. N TR Linwood TL Peter TR Walden TR RiverChase on right

SUBDIVISION Walden Ridge. BLOCK / SECTION LOT # 216 LOT AREA 1.18Ac. DESIGN FLOW 480gpd L.T.A.R. .3

Septic Tank 1000 Gallons: STB 7400 Date 8-27

Pump Tank 1000 Gallons: P T 3633 Date 7-13

Pump Make Goulds Model WE5T1Z4 Serial #

Nitrification Field No Fields 1 No Lines 4 Linear Feet 400'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type I II III IV V VI

System Description: Pump-PM-25% Reduction

Repair System Description: Pump-LP-PPBPS

Maintenance Agreement Required ☐ YES ☒ NO Not initially

☒ GRAVITY ☒ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: Initial site evaluation done by Rollans Soil & Environmental Services Reviewed floor plans 5/23/13 in compliance with Septic plan. Note: Bonus Room should have Cased or arched entry.

INITIAL SITE SKETCH

See plan by Rollans Soil & Environmental Services

Comments / Conditions: * Must keep Drainfield at least 25Ft from basement wall. Hug side property line with driveway * Keep tanks 15Ft from Basement.

AS BUILT SKETCH

This permit/plan approval replaces previous permit issued 9/5/07.

** Hug Property line with drive

400' INSTALLED

CHECKED FEB 24 2014
LINES & TANKS
RA

CHECKED MAR 24 2014
Pressure + Alarm + Circuits
ALP

Location of the proposed 15'x32' pool addition does not appear to impact the existing on-site septic system or well.** NOTE: #205441

Dane Grey REHS Date: 9-9-14

ICHD Environmental Health Division

*SEE SITE PLAN SUBMITTED BY MICHAEL ATHANAS *

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w / plat valid without expiration* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: [signature] Date 9/28/09

Improvement Permit by: Maria Hite Thomas RS Date 9/17/09

Authorzation to Construct by: Maria Hite Thomas RS 5/23/13

Installed by: GROUNDBREAKERS

Operation Permit by: [signature] Date: 3-24-14

Existing System Inspected by: Date:

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION!

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant