IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 135598 PIN# 4676 72 2722 DATE 6/5/06

OWNER OR APPLICANT Alan & Sharon Syler

ADDRESS 215 Bradford Glen Dr. Mooresville NC 28115 PHONE: Business _____ Home _____

LOCATION N. Main TR Linwood, TL Tecter TR Walden Ridge TR Riverchase TL Walnut Hill, on Lt

SUBDIVISION Walden Ridge BLOCK / SECTION _____ LOT 47 LOT AREA 1.02 Ac SITE CLASS. PS DESIGN FLOW 480 L.T.A.R. 0.3

Septic Tank: 1000 Gallons: STB 194 Date 3-5-01

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4 or 5 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth _____

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% Reduction

Repair System Description: Same

Maintenance Agreement Required: ☐ Yes ☒ No

☒ House/Mod. Home No. Bedrooms 4

☐ Mobile Home No. Persons _____

☐ Business No. Employees _____

☐ Other _____

Water Supply: ☒ Individual ☐ Public ☐ Community

☒ Gravity ☐ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: House is 85' From Front Prop. Line.

1"=50'

Comments:/Conditions: Note: Okay to do with "Burlin" drop boxes eff Quick 4

Checked ST # 4 of 5 lines (Quick 4

INITIAL SITE SKETCH

River chase

AS BUILT SKETCH

Location of the proposed 18' x 36' SWIMMING POOL addition does not appear to impact the existing on-site septic system.**NOTE: KEEP MIN. 15' FROM REPAIR AREA

R. STEVE HEDRICK REHS

Date: SEPT. 25, 2012

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Shawn C. Sublett date 6-21-06

Improvement Permit by: RS date 6/5/06

Authorization to Construct by: RS date 6/5/06

Installed by: Curt Brannon RS

Operation Permit by: Main Sanitarian date 4/25/07

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK