Pd $215.00 5/13/10 MD

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134589 PIN# 4676723953 DATE 5-13-2010

OWNER OR CONTRACTOR Barry Poris PHONE: Business 704 746 5046 Home 704 799 8557

ADDRESS 121 River Chase Ln. Mooresville NC 28115

LOCATION Linwood Rd TL Teeter TR Walden Dr TR Riverchase Ln

SUBDIVISION Walden Ridge BLOCK / SECTION _____ LOT 49 LOT AREA 1 acre SITE CLASS. PS DESIGN FLOW 480gpd T.A.R. .3

Existing Septic Tank: 1000 Gallons; STB _____ Date _____

Pump Tank: _____ Gallons; PT _____ Date _____

Pump Make: _____ Model _____ Serial No. _____

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400'

No Lines 4 Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

X New System ☐ Repair System Type: I, II, III, IV, V, VI

System Description: X Relocate Gravity 25% Reduct

Repair System Description: Grav. 50% Reduct

Maintenance Agreement Required: ☐ Yes X No

X House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Bathrooms ____ No. Employees ____

☐ Slab ☐ Crawl Space X Basement w/plumbing ☐ Basement wo/plumbing

Water Supply: X Individual ☐ Public ☐ Community

Comments:/Conditions: Moving existing Drainfield to install "Sports Court" in area of existing Drainfield.

Comments:/Conditions: Existing Septic tank will remain the same

INITIAL SITE SKETCH

See attached plan by Rollans Soil & Env. Services

AS BUILT SKETCH

Infiltrator Quick-4 Installed

4 Lines = 25 Chambers Each

Installed As Shown

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration. Improvement Permit with site plan valid for sixty months. Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: X _____

Improvement Permit by: _____ date 5/13/10

Authorization to Construct by: _____ date 5/13/10

Installed by: _____

Operation Permit by: _____ date 6-30-10

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 134589 PIN# 4676 72 3953 DATE April 18, 2006

OWNER OR APPLICANT Iredell Group LLC PHONE: Business 704 344 5944 Home

ADDRESS 104-C Williamson Rd, Mooresville, N.C. 28117

LOCATION Linwood Rd. (S) TL Teeter Rd. TR Walden Dr. TR Riverchase Ln.

SUBDIVISION Walden Ridge BLOCK / SECTION LOT 49 LOT AREA 1 Ac SITE CLASS. PS DESIGN FLOW 460gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 994 Date 3-16-07

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No. Fields 1 Square Feet 1200 Linear Feet 400

No Lines 4@100'± Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth NA

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: Gravity 25% Reduction

Repair System Description: SAME

Maintenance Agreement Required: ☐ Yes ☒ No

☒ Gravity ☐ Pressure

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Comments:/Conditions:

INITIAL SITE SKETCH

SEE PLAN FROM ROLLINS SOIL & ENV. SERVICES

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: date 4-24-06 Installed by: Tarheel Septic

Improvement Permit by: date 4-18-06 Operation Permit by: date 4-25-07

Authorization to Construct by: date 5/11/06 Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK