IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 13954 PIN# ~~4676 92 6992~~ 4676 727 930 DATE Dec 19, 05

OWNER OR APPLICANT Iredell Comp LLC PHONE: Business _____ Home _____

ADDRESS 109-C Williamson Rd, Mooresville, N.C. 28117

LOCATION Linwood Road Tract on Teeter Rd TR Walden Ridge TR Riverchase TR Walnut Hill at end on left

SUBDIVISION Walden Ridge BLOCK / SECTION _____ LOT 46 LOT AREA 3.41Ac SITE CLASS. PS DESIGN FLOW 400gpd L.T.A.R. .3

Septic Tank: 1000 Gallons; STB 312 Date 5-11-12
Pump Tank: _____ Gallons; PT _____ Date _____
Pump Make: _____ Model _____ Serial No. _____
Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400
No Lines 4 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI
System Description: Gravity 25% Reduction
Repair System Description: Same
Maintenance Agreement Required: ☐ Yes ☒ No
Gravel Depth NA ☒ Gravity ☐ Pressure

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons _____
☐ Business No. Employees _____
☐ Other _____

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☐ Crawl Space ☒ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Critical site evaluation and system design performed by Rollins Soil & Env. Services

Comments:/Conditions:

INITIAL SITE SKETCH

ST shall be 15' sideslope from basement

Install drainfield as shown on site plan

SEE Plan from Rollins Soil & Env. Services

AS BUILT SKETCH

ARC 360 CHAMBERS USED

INSTALLED AS SHOWN ON SKETCH

The proposed / existing POOL addition does not appear to impact the existing septic system.

**NOTE: KEEP ADD 15' FROM SEPTIC & REPAIR

R.S.

Date: 4/24/13

ICHD-Environmental Health Division

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Lisa Compton

Improvement Permit by: _____ date 12-19-05

Authorization to Construct by: _____ date 12-13-11

Installed by: _____

Operation Permit by: _____ REHS date 6-25-12

Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK