Old # 131978

IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3620

PERMIT # 207225

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # 4676-72-8591

APPLICANT: NATHAN MARION APPLICANT ADDRESS: 17932 RIVER FORD DR. DAVIDSON

SITE ADDRESS: 122 WALNUT HILL COURT - Mooresville PHONE: 704-576-3887 ALT. PHONE:

SITE DIRECTIONS: TEELER, TL WALDEN RIDGE, TR RIVERCHASE, TL WALNUT HILL, C END

SUBDIVISION: WALDEN RIDGE SECTION: LOT # 44 LOT AREA: 5.2AC DESIGN FLOW: 480 L.T.A.R.: .3

Septic Tank 1000 (gal) STB Date

Pump Tank (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 3 Linear Ft: 400'

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth —

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: 25% REDUCTION

Repair System Description: PANEL BLOCK

Maintenance Agreement Required: ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☐ Crawl Space

☒ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: If Infiltrator plastic ST installed 9/22/16

11/2/16 Renewed Floor plans, in Compliance with IP

INITIAL SITE SKETCH

SEE PLAN FROM MICHAEL ATHANAS & ASSOCIATES

AS BUILT SKETCH

Checked 1st 2 Lines 9-21-16 SA

Checked 3rd line & ST 9/22/16

Installed Quick 4

Essentially as Drawn

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 01/06/16 Installed by: Tommy Frye Craig Thompson

IMPROVEMENT PERMIT by: APPROVED Date: NOV 2 4 2015 OPERATION PERMIT by: RS Date: 9/22/16

AUTHORIZATION TO CONSTRUCT by: RS Date: 11/2/16 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

APPROVED NOV 2 4 2015

BA

