09361

4676797925

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Theresa B. Araya DATE 12/21/88 PERMIT NO. _____

PHONE: Business _____ Home ~~663-3679~~ 663-7734

LOCATION 152 E TR on 1151 1 mile on R.

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

Rt 10 Box 514 Mooresville Caddle Crk 1G-A-33 TAX #

House ( ) 2 Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 6 No. Bathrooms 4

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Sandy clay loam
Percolation Rate soil boring from 4/20/77
Topography _____
Depth to Water Table 10'+
Rock or other impervious formations none

Lot Area acreage

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NOT TO SCALE

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 1250 Linear Ft. 500'
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by J. R. Bowles

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: No sign of sewage seen at date of this inspection. Septem was originally sized for 2 mobile homes; therefore it is approved to continue to be used as such.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: Andrew C. Price DATE 12/21/88

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold