DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Michael Maher APPLICANT:
ADDRESS: APPLICATION DATE: DATE EVALUATED: 4/1/97 - 4/3
PROPOSED FACILITY: 4 Bdrm Hse PROPOSED DESIGN FLOW (.1949): 480 gpd PROPERTY SIZE:
LOCATION OF SITE: PROPERTY RECORDED:
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-12"	Rd C mSBK	SS,SP,SE,F	w/some yellow Relic mottles				
		12"-48"	Rd Cl wSBK	SS,SP,SE,F					
2	4% L	0-8"	SCL GR Brn	SS,SP	w/some yellow relic mottles				
		8"-24"	Rd-Brn C mSBK	S,P,SE					
		24"-32"	Rd-Brn Cl wSBK	SS,SP,SE					
		32"-48"	Cl SAP Rd Brn						
3		0-3"	SCL GR Brn	SS,SP					
		3"-23"	Rd-Brn C mSBK	SS,SP,SE					
		24"	SAP SL						
4		0-8"	GR SCL GR						
		8"-20"	Rd-Brn C mSBK	S,P,SE					
		20"-32"	Rd-Brn C SBK	SS,SP,SE					
		32"	SAP						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)	Gravity Conventional	Gravity Conventional
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): P.S
EVALUATED BY:
OTHER(S) PRESENT:

DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Michael Mahr APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 12/2/97
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Teeter Rd PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (1941) 1941 STRUCTURE/ TEXTURE	1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS 1942 SOIL WETNESS/ COLOR	1943 SOIL DEPTH	1956 SAPRO CLASS	1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1		D-6"	Brw SCL						PS .25-.3
		6"-24"	Rd/Brw C/CL S,P,SE,F						
		24"-48"	Rd/Brw CL S,SPSE,F-FR w/Inclus of SAP, rock fragments & Chroma 2 Relic matrix						
2		D-5"	Brw SCL GR						PS .3 24"-36"
		5"-24"	Rd/Brw C/CL SBK S-SS,D-SPSE,F-FR						
		24"-36"	Rd/Brw CL SBK SS,SPSE,FR						
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____