~~4677170682~~

IREDELL COUNTY HEALTH DEPARTMENT 4677077324

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Keith Carpenter DATE 7/27/89 PERMIT NO. IN-10-A-1

PHONE: Business _____ Home 664-1121

LOCATION N. Main St. On L. across from Custom Products. 1st lot on left in Carpenter Acres. S. R. No. _____

SUBDIVISION NAME Carpenter Acres LOT NO. 1 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No	(✓)
Auto. Dishwasher	Yes (✓)	No	( )
Auto. Wash. Machine	Yes (✓)	No	( )
Site Suitable	Yes (✓)	No	( )

Character & Porosity of Soil clayey
Percolation Rate .4 gpd/ft²
Topography hgt
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area .98A

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓) on lot 3.
Public ( )

Installed by Rowan Septic Service George Kirkpatrick

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Andre C. Pierce, R.S.

COMMENTS: Elm watershed area.

CERTIFICATE OF COMPLETION BY Andre C. Pierce, R.S. DATE July 27, 1989

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold