1154

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Keith S. Carpenter DATE 5/4/89 PERMIT NO. _____

PHONE: Business _____ Home 664-1121

LOCATION N. Main St. On L across from Custom Products 4th lot on left in Carpenter Acres S. R. No. _____

SUBDIVISION NAME Carpenter Acres LOT NO. 4 SECTION OR BLOCK NO. _____

IN-10-A-4 Caddle Creek

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area ~~200~~ 40000ft²+

Character & Porosity of Soil clay


Percolation Rate .4gpd/ft²

Topography rolling

Depth to Water Table over 4'+

Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: ~~X~~ Keith Carpenter

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: Install system at a shallow depth of 24"-30". Keep ditches level and on contour.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold