4677-26-9319

1457

IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Marshall Horsman DATE 10/20/92 PERMIT NO. IN-9-B-14

PHONE: Business _____ Home _____

LOCATION 152E TR into Pickwyck Village - straight to cul de sac drive swiftly ahead. S.R. No. _____

SUBDIVISION NAME Pickwyck Village LOT NO. 14 SECTION OR BLOCK NO. 1

House ☑ Mobile Home ☐ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes ☑ No ☐

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 40,000 FT²

Soil Characteristics P-C / TRANS


Application Rate P-.4

Topography P-2-4%

Depth to Water Table 5-48"

Rock or other impervious formations 5 - None observed

_____ Basement with Plumbing Replacement _____ Basement without Plumbing _____ No Basement ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ☑ Public ☐

Installed by Horsmen

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY _____

COMMENTS _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 10/20/92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

1457

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Marshall Horsman DATE Aug 26, '91 PERMIT NO. IN-9-B-14

PHONE: Business _____ Home _____

LOCATION 152 E Rinto Pinewyck Village at end

SUBDIVISION NAME Pinewyck Village LOT NO. 14 SECTION OR BLOCK NO. _____ S. R. No. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable ~~PS~~ Yes (✓) No ( )

Lot Area 40,000 sf±

Character & Porosity of Soil PS clay trans


Percolation Rate 1 in 4 @ 30"-36"

Topography 2-4%

Depth to Water Table 44

Rock or other impervious formations more obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3-4

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed ~~X~~ Donald Horsman

IMPROVEMENTS PERMIT BY D R Hinson, RS.

COMMENTS:

follow contour with drainfield, install trenches at 30-36" trench bottom.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold