0623

13:00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR TCR Sales Inc. DATE 6-22-87 PERMIT NO.

PHONE: Business Home

LOCATION N. Main TR just before pit with 150 By Pass 1st Lot on Rt S. R. No.

SUBDIVISION NAME Hickory Creek Village LOT NO. 27 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area ~30000 sq ft

Character & Porosity of Soil clay {rebic mottles present drainage not to be 3'+


Percolation Rate ~35

Topography 2-4% to 3'+

Depth to Water Table 3'+

Rock or other impervious formations none obs

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft 1035 Linear Ft. 345

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: D. L. Jarrell

IMPROVEMENTS PERMIT BY Jarrell Hanson R.S.

COMMENTS: Install drainfield shallow (12" cover). Follow contour

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold