DEPARTMENT OF HUMAN RESOURCES
DIVISION OF HEALTH SERVICES

SITE/SOIL EVALUATION FOR SANITARY SEWAGE SYSTEM

OWNER: LARRY MORROW PHONE: 664-3206 DATE REQUESTED: 1/10/94 DATE EVALUATED: 1/10/94

ADDRESS: _____ PROPERTY IDENTIFICATION NO.: 1N9 B12

COUNTY: _____ PROPERTY SIZE: _____ PROPOSED FACILITY: 3BD - 2BA - CRAWL

LOCATION OF SITE: LOT 12 PICWYCK VILLAGE

WATER SUPPLY: On-Site Well ✓ Community ____ Public ____ EVALUATION BY: Auger Boring ✓ Pit ____ Cut ____

FACTORS	PROFILE 1	PROFILE 2	PROFILE 3	PROFILE 4	PROFILE 5
LANDSCAPE POSITION	T L				
SLOPE(%)	0-3				
HORIZON I DEPTH	0-4				
Texture Group	sl				
Consistence	Fr Ss Sp				
Structure	gr				
Mineralogy	1:1				
HORIZON II DEPTH	5-12				
Texture Group	SC				
Consistence	sFi S Sp				
Structure	wk sbk				
Mineralogy	1:1				
HORIZON III DEPTH	13-27				
Texture Group	SaL C TRANS				
Consistence	F S Sp				
Structure	wek				
Mineralogy	1:1				
HORIZON IV DEPTH	28-34				
Texture Group	TRANS SaL				
Consistence	Fr NS Np				
Structure	gr				
Mineralogy	1:1				
SOIL WETNESS	P				
RESTRICTIVE HORIZON	NIH				
SAPROLITE	P				
CLASSIFICATION	P				
LONG-TERM ACCEPTANCE RATE	.25-.3				

SITE CLASSIFICATION: P SITE LONG-TERM ACCEPTANCE RATE: .3

EVALUATED BY: SPARKS OTHER(S) PRESENT:

REMARKS:

Tricky topography. Lines waste a lot of space when run on contours.

LEGEND

LANDSCAPE POSITION
R - Ridge
S - Shoulder slope
L - Linear slope
FS - Foot Slope
N - Nose slope
H - Head slope
Cc - Concave slope
Cv - Convex slope
T - Terrace
FP - Flood Plain

TEXTURE
s - sand
ls - loamy sand
sl - sandy loam
l - loam
si - silt
sil - silt loam
sicl - silty clay loam
cl - clay loam
scl - sandy clay loam
sc - sandy clay
sic - silty clay
c - clay

CONSISTENCE
Moist
vfr - very friable
fr - friable
fi - firm
vfi - very firm
efi - extremely firm

Wet
Ns - non-sticky
Ss - slightly sticky
S - sticky
Vs - very sticky

Np - non-plastic
Sp - slightly plastic
P - plastic
Vp - very plastic

STRUCTURE
sg - single grain
m - massive
cr - crumb
gr - granular
sbk - subangular blocky
abk - angular blocky
pl - platy
pr - prismatic

MINERALOGY
1:1, 2:1, mixed

Use the above standard abbreviations.

NOTES:
Horizon Depth --in inches
Depth of Fill --in inches from land surface
Restrictive Horizon--thickness and inches from land surface
Saprolite --S (suitable) or U (unsuitable)

NOTES:
Soil Wetness --inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less--record Munsell color chip designation
Classification--S (suitable), PS (provisionally suitable) or U (unsuitable)
Long-Term Acceptance Rate--gal/day/ft²

DHS 2601 (Revised ____)
Sanitation Branch (Review ____)