4677-36-2912

IREDELL COUNTY HEALTH DEPARTMENT

1449

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James D Mehaffey DATE 5/17/91 PERMIT NO. IN9-B-9

PHONE: Business _____ Home 896-4642

LOCATION Pickwyck Village

S. R. No. 150E

SUBDIVISION NAME Pickwyck Village LOT NO. 7 SECTION OR BLOCK NO. II

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clay-scl (sp)
Percolation Rate .35
Topography 2-5% sloping
Depth to Water Table >48"
Rock or other impervious formations No

Lot Area 20,000FT.

Basement with Plumbing ____ Basement without Plumbing ____ No Basement ✓



Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 3@ 126'x3'
Sq. Ft. 945 Linear Ft. 315
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Ray Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Wesley Sparks RS. DATE 5/17/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

1449

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James D. Mahaffey DATE 4/19/91 PERMIT NO. IN9-B-7

PHONE: Business _____ Home 876-4642

LOCATION Pickwych Village Lot #7

S. R. No. 1506

SUBDIVISION NAME Pickwych Village LOT NO. 7 SECTION OR BLOCK NO. II

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2.5

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clay - mod P

Percolation Rate 35


Topography 2-5% sloping

Depth to Water Table > 48"

Rock or other impervious formations No

Lot Area 20,000 Ft²

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Street Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3@105'

Sq. Ft. 945 Linear Ft. 315

Depth of Stone in Lines 12-14"

Water Supply: Individual (✓)

Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: Jeff Elder

IMPROVEMENTS PERMIT BY Wesley Sparks R.S.

COMMENTS: Keep bottom trenches no deeper than 36" - Drop boxes need to be used on this slope. Repair area must be above the unsuitable gully area on the lower (right) side of this lot.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold