4677390580

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR William E Tilbert DATE 3-30-04 PERMIT NO. 236

PHONE: Business _____ Home 463-2676

LOCATION 150 East TL on Wiggins Rd Turn
Right 2nd Entrance in corner S. R. No. _____

SUBDIVISION NAME Woodland Heights LOT NO. 5 SECTION OR BLOCK NO. _____


House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes	( )	No	(✓)
Auto. Dishwasher	Yes	(✓)	No	( )
Auto. Wash. Machine	Yes	(✓)	No	( )
Site Suitable	Yes	(✓)	No	( )

Lot Area 2 Acre

Character & Porosity of Soil Loam Clay loam Porosity
Percolation Rate Not Given
Topography Slope
Depth to Water Table 18"+
Rock or other impervious formations None



Proposed Accessory Bldg

Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 250 Linear Ft. 300
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by E T Spivey

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

Location of the proposed Accessory Bldg addition does not appear to impact the existing on-site septic system.**NOTE: shall be min. 25' from well & min. 5' from septic

Audrey Melville REHS
Date: 5-16-13
ICHD-Environmental Health Division

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 5-30-04

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold