IREDELL COUNTY HEALTH DEPARTMENT 4677391775

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Thomas Sr. DATE 10-22-24 PERMIT NO. _____

PHONE: Business _____ Home _____


LOCATION 15A East T.L. on Wagner Rd 21 TR into Woodland Heights S. R. No. _____

SUBDIVISION NAME Woodland Heights LOT NO. 13 SECTION OR BLOCK NO. _____

House ( ) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area 3 acres

Character & Porosity of Soil Sandy clay loam Porosity Percolation Rate Not taken Topography Gentle Slope Depth to Water Table 24" Rock or other impervious formations None



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 450 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual ( )
Public ( )

Installed by E.T. Sain

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 10-30-24

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold