4677392795

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Buddy Surrogood DATE Jan. 22, 80 PERMIT NO. 7

PHONE: Business _____ Home _____

LOCATION 152 E. TL on 2339 - TR into Woodland Heights ~1/4 mi on Rt. S. R. No. _____


SUBDIVISION NAME Woodland Heights LOT NO. 14 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay loam
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	80-120 min
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	6-8%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	sunk.
			Rock or other impervious formations	none obs.

Lot Area 120 X 185



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 16"

Water Supply: Individual (✓)
Public ( )

Installed by Grier Brown

IMPROVEMENTS PERMIT BY F.A.C.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Charles R. Hinson DATE Jan. 22, 80

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold