4677-48-7592

IREDELL COUNTY HEALTH DEPARTMENT

10774

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Rodney Lewis DATE May 14, '90 PERMIT NO. IV-8-A-8

PHONE: Business _____ Home _____

LOCATION 150 E TL into Oakmeadow ~500' on left

S. R. No. _____

SUBDIVISION NAME Oakmeadow LOT NO. 8 SECTION OR BLOCK NO. _____

House (4) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (4)

Auto. Dishwasher Yes (4) No ( )

Auto. Wash. Machine Yes (4) No ( )

Site ~~Suitable~~ RS Yes (4) No ( )

Lot Area .97Ac

Character & Porosity of Soil Psclay

Percolation Rate 1-40 35 0


Topography 2-4%

Depth to Water Table 4'+

Rock or other impervious formations numerous outcrops rock

Q Neighbors well

_____ Basement with Plumbing ✓ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 1080 Linear Ft. 360

Depth of Stone in Lines 12"

Water Supply: Individual (4)

Public ( )

Installed by J. Rory (Salisbury NC)

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DR Hunter

COMMENTS: Plumbing pulled out high enough and filled around house to eliminate pump.

CERTIFICATE OF COMPLETION BY David R. Hunter, EHS DATE 5-14-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold