IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John Meese DATE 11/2/87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 150 E (By Pass TL into Oak Meadow on left @ Cul de Sac. S. R. No. _____

SUBDIVISION NAME Oak Meadow LOT NO. 13 SECTION OR BLOCK NO. _____

4677-49-8169


House (✓) Mobile Home ( ) Business ( ) Other ~~Restaurant~~

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	2.4
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-10%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none observe

Lot Area 20000 ft²

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Pump Tank 1000 gal.

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Benny Mayne
Installed by Rockwell Radio & Electric

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH

COMMENTS: Cked Tanks, lines, adjusted flow to lines. -ACP 11/2/87
Ck high water alarm, Ck floats, all -ACP
11/23 - High water alarm works
~~Both~~ BOTH FLOATS INSTALLED

CERTIFICATE OF COMPLETION BY Andrew C Penn DATE 11/23/87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold