IREDELL COUNTY HEALTH DEPARTMENT - *ENVIRONMENTAL HEALTH* ☐ STATESVILLE OFFICE 704-878-5305 ☒ MOORESVILLE OFFICE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # 17134 PIN # 4677-57-1590 DATE 4-11-12

OWNER KENNETH CHRISTIANA APPLICANT: SAME PHONE: Home/Cell # Business #

SITE ADDRESS 1307 OAKRIDGE ~~Hwy~~ FARM Hwy OWNER / APPLICANT ADDRESS SAME

SITE DIRECTIONS

SUBDIVISION — BLOCK / SECTION — LOT # — LOT AREA .87AC DESIGN FLOW 360 L.T.A.R. .4

Septic Tank 1000 Gallons: STB 794 Date 2-19-12
Pump Tank Gallons: P T Date
Pump Make Model Serial #
No. Nitrification Fields: 1 No. Lines 2 Linear Feet 224'
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth —

☒ New System ☐ Repair ☐ Expansion System Type I II (III) IV V VI
System Description: 25% G.
Repair System Description: 25%
Maintenance Agreement Required ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 3
☐ Business No. Persons
☐ Other No. Employees
☐ Slab ☒ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions


The proposed / existing ADDITION & BUILDING RELOCATION addition does not appear to impact the existing septic system.


**NOTE: R.S.

Date: 8-30-12

ICHD-Environmental Health Division

INITIAL SITE SKETCH





Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration.* ☐ ***IMPROVEMENT PERMIT*** *with plat valid without expiration. site plan valid 60 mo.* ☒ ***AUTHORIZATION TO CONSTRUCT*** valid for period equal to IMPROVEMENT PERMIT–not to exceed 60 mo.

Owner / Applicant Signature: Date 4/11/12 Installed by:

IMPROVEMENT PERMIT by: REHS Date 4-11-12 OPERATION PERMIT by: LARRY BEAM REHS Date 4-25-12

AUTHORIZATION TO CONSTRUCT by: REHS Date 4-11-12 Existing System Inspected by: REHS Date

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

White Copy – Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant