IREDE COUNTY HEALTH DEPARTMENT STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT # REPAIR PIN # 4677-67-1945 DATE 6-24-10

OWNER or APPLICANT KRIS PEEBLES PHONE: Business 704-664-5744 Home:

OWNER or APPLICANT ADDRESS 1355 OAKRIDGE HWY

LOCATION / DIRECTIONS 150 TOWARDS SALISBURY, JUST PAST PEEBLES AUTO

SUBDIVISION BLOCK / SECTION LOT # LOT AREA 2.5Ac DESIGN FLOW 240 GPD L.T.A.R. .15

Septic Tank Ex 1000 Gallons: STB Date

Pump Tank Gallons: P T Date

Pump Make Model Serial #

Nitrification Field No Fields 1 No Lines 5 Linear Feet 400'

Trench Width 36" Max. Trench Bottom Depth 18" Gravel Depth —

☐ New System ☒ Repair ☐ Expansion System Type I II III IV V VI

System Description:

Repair System Description: GRAVITY 25% REDUCTION

Maintenance Agreement Required ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 2

☐ Business No. Persons

☐ Other No. Employees

☐ Slab ☒ Crawl Space

☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions 1) INSTALL BULL RUN VALVE FOR FUTURE USE 2) IF OLD TANK IS IN BAD SHAPE INSTALL NEW 1000 GALS) INSTALL FILTER IN TANK

Comments / Conditions

INITIAL SITE SKETCH

1" = 50'

DRIVE WAY

184'

HWY

150'

HOUSE

OLD SEPTIC

FLOWER BED

EXISTING TANK

SHED

SHED

BULL RUN

TOLD RICHARD ABERNATHY NO BAFFLE IN TANK WAS OK BUT NEEDED FILTER

TANK DOES HAVE BAFFLE

AS BUILT SKETCH

GARAGE

FILTER INSTALLED

ARC36 CH INSTALLED AS DRAWN

BULL RUN VALVE NOT INSTALLED

OLD TANK LOOKS GOOD

USED END CAPS FOR DISTRIBUTION

80' 80' 80' 80' 80'

629'

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.

☐ *IMPROVEMENT PERMIT w/ plat valid without expiration.* ☐ *IMPROVEMENT PERMIT w / site plan valid for 60 mos.* ☐ *AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT-not to exceed 60 mo.*

Owner / Applicant Signature: Kris Peebles Date 6-25-10

Improvement Permit by: REHS Date 6-25-10

Authorzation to Construct by: REHS Date 6-25-10

YOU SHOULD CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION.

Installed by: RICHARD ABERNATHY

Operation Permit by: REHS Date: 7-14-10

Existing System Inspected by: Date:

WHITE COPY Environmental Health YELLOW COPY (Final) Owner / Applicant PINK COPY (Initial) Owner / Applicant