DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Tim Worrell APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: 3 BD 2BA PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 3.2 ac
LOCATION OF SITE: Lot 203 Pinnacle Rd. PROPERTY RECORDED: _____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	T 3%	0-10	GR / msl	FR SS SP					PS .4
		11-26	GR / scl - SAP	VFR SS NP					
		27-46	GR / (cl) - SAP	VFR SS NP					
2	LS 5-6%	0-10	ASCL WSBK	FR SS SP					.3
		11-29	CL WSBK	FR SS SP					
		29-44	L-SAP WSBK	FR SS, SP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	5	5
System Type(s)	CONV	SAME
Site LTAR	.3	.3

OTHER FACTORS (.1946): 46" Soil/SAP Depth CREEK
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Sparks / Freeman
OTHER(S) PRESENT: _____