IREDELL COUNTY SOIL/SITE EVALUATION

OWNER	RALPH GRAHAM	GPD	360	LOT SIZE	.99 AC	
APPLICANT	WAYNE ERVIN	P. FACILITY	SFR	RECORDED		Y
ADDRESS	1527 OAKRIDGE HWY					
SUBDIVISION	POWERS ESTATES		SECTION		LOT #	3
WATER SUPPLY		PUBLIC	X INDIVIDUAL	X WELL	SPRING	OTHER

	MORPHOLOGY			PROFILE FACTORS				
PROFILE LANSCAPE POSITION SLOPE	H. DEPTH	STRUCTURE TEXTURE	CONSISTENCE MINEROLOGY	WETNESS COLOR	SOIL DEPTH	SAP CLASS	REST. HORIZON	LTAR
AB 1	0-16	SCL,M,SBK	SS,SP,SEXP,VFR	NA	48"	MANY @ 37"	48+	0.35
	16-20	C,M,SBK	SS,SP,SEXP,FR					
LINEAR	20-48	SCL,W,SBK	SS,SP,SEXP,VFR					
4%								
AB 2	0-31	CL,W,SBK	SS,SP,SEXP,VFR	NA	48"	MANY THROUG HOUT	48+	0.35
	31-48	SCL,W,SBK	SS,SP,SEXP,VFR					
LINEAR								
5%								

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM	OTHER FACTORS	
AVAILABLE SPACE		PS	SOIL EVALUATION BY	BEN ALDRIDGE
SYSTEM TYPE		CHAMBER BED	SITE EVALUATION BY	BEN ALDRIDGE
SITE LTAR		0.35	OTHERS PRESENT	WAYNE ERVIN