owes $450

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 149508 PIN# 4678063920 DATE 5-6-08

OWNER OR APPLICANT Alan Harwood PHONE: Business 704-799-0459 Home

ADDRESS 149 Flowering Grove Ln Mooresville NC 28115

LOCATION 801 Cross 150 Aprox 1.5 miles on left

SUBDIVISION — BLOCK / SECTION — LOT 13+14 LOT AREA 1.53 AC SITE CLASS PS DESIGN FLOW 360 L.T.A.R. .11

Septic Tank: 1000 Gallons: STB 760 Date 8/2/08

Pump Tank: 1000 Gallons: PT 363 Date 3/8/08

Pump Make: ZOELLER Model BN140-F Serial No. 11/08

Nitrification Field: No Fields 1 Square Feet 3300' Linear Feet 660'

No Lines 6 Trench Width 8-18" Max Trench Bottom Depth 12" Gravel Depth 11" ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI

System Description: LPP

Repair System Description: Pretreatment Drip

Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 3 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments:/Conditions: Closely follow design specifications from Michael Athanas + Associates / Installer shall not begin installation without design specs from Michael Athanas

Comments:/Conditions: 35' from corner

INITIAL SITE SKETCH

SEE ATTACHED PLAN FROM MICHAEL ATHANAS + ASSOCIATES

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: _____ date 5/8/08 Installed by: Danny Revis

Improvement Permit by: J-Allen date 5-6-08 Operation Permit by: Wesley Sparks RS. date 3/25/09

Authorization to Construct by: J-Allen date 5-22-08 Existing System Inspection by: _____ date _____

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK