IREDELL COUNTY HEALTH DEPARTMENT

13771 (SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James A Brown DATE 12/20/91 PERMIT NO. 4C-A-7

PHONE: Business _____ Home 663-4072

LOCATION 801 N on Left just above the Zoo Sewage yard. T L on gravel to end of driveway S. R. No. _____

SUBDIVISION NAME N/A LOT NO. N/A SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil P - C (SS - SL)
Percolation Rate .4 mpi 24"
Topography 2-4%
Depth to Water Table > 48"
Rock or other impervious formations No

Lot Area 20,000

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3@100'x3'
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓) Brown well
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed James A Brown

IMPROVEMENTS PERMIT BY Wesley Sparks RS

COMMENTS: Trailers and driveways must be kept off the drainfield areas. Drainfield CANNOT go in the depressional area due to poor drainage and surface water infiltration

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold