# IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 20723

## IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # [redacted]8-44-5726

APPLICANT: 10 Homes APPLICANT ADDRESS: 840 Edminston Rd. Mt. Ulla

SITE ADDRESS: 1562 Wiggins Rd PHONE: 704-400-0472 ALT. PHONE:

SITE DIRECTIONS: 150 W, TR Wiggins, on L

SUBDIVISION: Meadows Farm SECTION: LOT # 3 LOT AREA: ~1 AC DESIGN FLOW: 480 L.T.A.R.: 275

Septic Tank 1000 (gal) STB 825 Date 2/4/15
Pump Tank (gal) PT Date
Pump Make Model Serial #
# Nitrification Fields 1 # Lines 4 @ 110' Linear Ft: 440'
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: 25% Reduction
Repair System Description: Same
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☒ Residence No. Bedrooms 4
☐ Business No. Persons
☐ Other No. Employees
☒ Slab ☐ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions: * Must Be Min 50' From Wells *

INITIAL SITE SKETCH

See Plan From Michael Athanas & Associates

AS BUILT SKETCH

Installed As Drawn.
Quick 4 Chambers

*Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system.* **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☒ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Date: 1/14/15 Installed by: Rowan Septic

IMPROVEMENT PERMIT by: Date: 1/14/15 OPERATION PERMIT by: APPROVED MAY 11 2015

AUTHORIZATION TO CONSTRUCT by: Richard Farris Date: 1/14/15 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK

N
158.21'
EX #4 REBAR
W/ BENBOW CAP
Scale
1"=50'
4
1.15 AC
3
1.00 AC
2
1.00 AC
60.0'
60.0'
80.0'
119.02'
29.5'
S48°32'56"E
368.80'
Well
50'
41.0'
60.0'
60.0'
80.0'
117.41'
5'
Pool
ST
40.7'
S48°32'56"E
247.00'
37.5'
60.0'
60.0'
80.0'
52.03'
81'
58.08'
4'
Leased
304.17'
S40°30'32"W
L7
L8
181.77'
188.42'
Pil-34'
Bldg
Rd-37'
Bldg-44'
Rd-99'-8"
Rd-95'
Rs-107'
W-44'-11"
D-110'
D-82'-11"
EX 3/4" PIPE
Barn that has been Removed
N
NOW OR FORMERLY
MARTHA & LUTHER COREN
DB 1225-281
351.02' TOTAL
248.58'
201.58'
189°26'49"E
AR CAP
APPROVED JAN 12 2014