DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 4C A 26
PROPERTY RECORDED: ___
COUNTY: IREDELL

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: JAMES MEADOWS SR. OWNER: ✓ AGENT: ___ PHONE: 633-0984
ADDRESS: WIGGINS RD. APPLICATION DATE: 6/7/93 DATE EVALUATED: 6/11/93
PROPOSED FACILITY: 3BD. HOUSE
PROPERTY SIZE: ~ 3AC
LOCATION OF SITE: WIGGINS RD.
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ✓

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	8-10% P	0-9	SBK - C	1:1	S	N/A		N/A	
		10-24	F WSBK - SC	1:1	S	N/A	—	N/A	
		25-31	F SBK - SIC	1:1	S	P	—	P	
		32-40	VF WSBK - C/TEMMS	1:1	S	P	—	P	.25-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25-.3
EVALUATED BY: Sparks OTHER(S) PRESENT: LOANN MEADOWS
COMMENTS: USE A BASEMENT CUT