DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET____OF____
PROPERTY I.D.#:____
PROPERTY RECORDED:____
COUNTY:____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: WENDELL + SUSAN HAIRE OWNER: ✓ AGENT:__ PHONE: 663-6713
ADDRESS: WIGGINS RD. APPLICATION DATE: 7/29 DATE EVALUATED: 7/29
PROPOSED FACILITY:____
PROPERTY SIZE:____
LOCATION OF SITE: WIGGINS RD (L) RE 150E, 2 MILES ON (L) BELOW BALLFIELD
WATER SUPPLY: On-Site Well ✓ Comm. Well___ Public___ Other____ EVAL. METHOD: Auger Boring ✓ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1		0-3	0 sg sil	1:1	wss-wpo dk	No	S	—	.35
		4-11	1 cr s l	1:1	wso-wpo do				
		12-32	1 sbk sc l	1:1	wso-wpo do				
		33-42	1 sbk sc l	1:1	wss-wpo do				
		43+	2 wk sbk sc	1:1	wss-wpo mfr				
2									
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .3-.35
EVALUATED BY: [signature] OTHER(S) PRESENT: Susan Haire
COMMENTS:____