IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Perry S. Windsor DATE June 6, 79 PERMIT NO. 190

PHONE: Business _____ Home _____

LOCATION 150 E past Co. line T.L. at end on left

S. R. No. _____

SUBDIVISION NAME Scottish Downs LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 4 No. Bathrooms 2½

Garbage Disposal Unit	Yes	(✓)	No	( )	
Auto. Dishwasher	Yes	(✓)	No	( )	
Auto. Wash. Machine	Yes	(✓)	No	( )	
Site Suitable	Yes	(✓)	No	( )	

Lot Area 9.17 AC.

Character & Porosity of Soil clay loam
Percolation Rate 80 mpi + 6-59
Topography _____
Depth to Water Table sunk.
Rock or other impervious formations none obs



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 1200 Linear Ft. 400
Depth of Stone in Lines 10"+
Water Supply: Individual (✓)
Public ( )

Installed by F.J. Erwin Const.

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 6-6-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold