4618802181

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Little DATE 12-11-79 PERMIT NO. 427

PHONE: Business _____ Home _____

LOCATION 150 E. Rt on 1167 on left at Co. line

S. R. No. _____


SUBDIVISION NAME Performance Properties LOT NO. 16 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area ~1 AC.

Character & Porosity of Soil clay loam
Percolation Rate 80 mpi
Topography 4-6%
Depth to Water Table sink.
Rock or other impervious formations none obs.



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by F.J. Erwin

IMPROVEMENTS PERMIT BY FAC

COMMENTS: _____

CERTIFICATE OF COMPLETION BY David R. Hinson DATE 12-11-79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold