DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 4H A 53
PROPERTY RECORDED: YES
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: RAYCE ANGELLEY OWNER/✓AGENT: __ PHONE: 663-4819
ADDRESS: R+1 Box 179 APPLICATION DATE: 7/23 DATE EVALUATED: 7/23/93
Mt Ulla, NC PROPOSED FACILITY: 3BD - 2BA D/W
PROPERTY SIZE: ~ 1.3 AC
LOCATION OF SITE: TRIPLETT RD. - 1 MILE FROM 801 N ON (R)
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	4% S	0-4	0 / SG / l	1:1	WSO-WPO				
		5-11	2 / sbk / cl	1:1	WS-WPO				
		12-33	3 / WD sbk / cl	1:1	WS-WPO	NA	P	NA	
		34-42	2 / sbk / l	1:1	WSO-WPO	NA	P	NA	.35-.3
2									
3									
4									
5									

AVAILABLE SPACE (.1945) P SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: Sparks OTHER(S) PRESENT: RAYCE ANGELLEY
COMMENTS: Trenches around 30" trench bottom - CB Horizon with best structure