IREDELL COUNTY HEALTH DEPARTMENT

Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 215761

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

PIN # ~~4079-27-0129~~ 17-8116

APPLICANT: LARRY EDWARDS APPLICANT ADDRESS: 1095 MAZEPPA

SITE ADDRESS: 1941 TRIPLETT RD.; Mt. Ulla PHONE: 704-663-4649 ALT. PHONE:

SITE DIRECTIONS: 801, TL TRIPLETT, ON R PAST WINTHROW CREEK

SUBDIVISION: SECTION: LOT # LOT AREA: 29.5 AC DESIGN FLOW: 360 L.T.A.R.: .3

Septic Tank 1000 (gal) STB 194 Date 2-22-16
Pump Tank (gal) PT Date
Pump Make Model Serial #
Nitrification Fields 1 # Lines 5@60' Linear Ft: 300'
Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI
System Description: 25% REDUCTION
Repair System Description: SAME
Maintenance Agreement Required: ☐ YES ☒ NO
☒ GRAVITY ☐ PRESSURE

☐ Residence No. Bedrooms 3
☐ Business No. Persons
☒ Other No. Employees
☐ Slab ☐ Crawl Space
☐ Basement w/plumbing ☐ Basement w/o plumbing

Water Supply: ☒ Private ☐ Public ☐ Community

Comments / Conditions:

BARN

~~21/2 From ST to Barn~~
~~21/2 From Drainfield to Barn~~

INITIAL SITE SKETCH

1"=100'

R 568'

TO TRIPLETT

R 280'

295'

DRIVE WAY

55'x48' BARN

REPAIR

5@60'

AST REPAIR

AS BUILT SKETCH

BARN ONLY TO BUILT AT THIS TIME. 3 BEDROOM SYSTEM PERMITTED IN CASE OF FUTURE IMPROVEMENTS.
Dranfield Installed as Drawn
ST Quickly moved up slightly

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. **CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION**

☐ **IMPROVEMENT PERMIT** *with plat valid without expiration.* ☒ **IMPROVEMENT PERMIT** *with site plan valid for 60 mos.* ☐ **AUTHORIZATION TO CONSTRUCT** *valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.*

Owner / Applicant Signature: Larry W Edwards Date: 2.4.16 Installed by: CW Orbison

IMPROVEMENT PERMIT by: Date: 1-29-16 OPERATION PERMIT by: Date: 3/28/16

AUTHORIZATION TO CONSTRUCT by: Date: 1-29-16 Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK