IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Clifford Settlemeyer DATE 11/4/87 PERMIT NO. _____

PHONE: Business _____ Home 663-2007

LOCATION 115N TR Mazeppa Rd. TL Triplett Rd. TR
Confederate on Right ~9th House (MH past 9th house) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 1
Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clayey
Percolation Rate 4.4 gpd/ft²
Topography 4-8%
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area 3.72 ACRE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 4
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12 inch
Water Supply: Individual (✓)
Public ( )

Installed by W. ORBISON

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACP

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Pierce DATE 11/4/87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

07552

4.00

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Clifford Settlemyer DATE 10/26/87 PERMIT NO. _____

PHONE: Business _____ Home 663-2007

LOCATION 115 N TR Mazeppa Rd TL Triplett Rd. TR Confederate on Right ~9th House. (M.H. past 9th house) S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 2 No. Bathrooms 1

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clayey
Percolation Rate ~.4 gpd/ft²
Topography 4-8% 70
Depth to Water Table 4'+
Rock or other impervious formations none observed

Lot Area 3.72 ACRE

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System NTS

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 600 Linear Ft. 200
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed Clifford Settlemyer

IMPROVEMENTS PERMIT BY Andrew C. Price

COMMENTS: Set tank off house (5') Run lines on contour and SHALLOW (30-36" to bottom of ditch. 2 4-boxes.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold