IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James C. Wineoff DATE 6-30-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 801 N. TR 2362 (Triplett Rd) TR 2388 (Confederate Rd) ~1/4 mile on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil shallow clay
Percolation Rate ~4 (60 44)
Topography _____
Depth to Water Table _____
Rock or other impervious formations sap - 30"+

Lot Area ~3Ac

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: James Wineoff

IMPROVEMENTS PERMIT BY David R. Johnson R.S.

COMMENTS: Follow contour with drainfield. Install drainfield no deeper than 30" to bottom of ditch. Do not cut soil of area of drainfield. Use drop boxes to distribute effluent.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold