IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

4350 1.00

PERMIT# 13926 PIN# 4679318736 4679315166 Inc DATE 9-14-07

OWNER OR APPLICANT T&E Developers LLC / LB Builders Business 892-9595 Home

ADDRESS 112 Vista Bluff Ln Mooresville NC 28117

LOCATION Hwy 801 TR Wiggins TR Savannah Crossing Dr at end

SUBDIVISION Kerr's Plantation BLOCK / SECTION LOT 9 LOT AREA 1.05Acre SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .275 to .3

1HP

Septic Tank: 1000 Gallons: STB 312 Date 7-22-08
Pump Tank: 1000 Gallons: PT 27 Date 6-9-08
Pump Make: Goulds Model WE1612HU Serial No
Nitrification Field: No Fields 1 Square Feet 945 Linear Feet 315
No Lines 4 Trench Width See Note Max Trench Bottom Depth 36 Gravel Depth N/A ☐ Gravity ☒ Pressure

☒ New System ☐ Repair ☐ Expansion System Type: I II III (IV) V VI
System Description: Pump-LP-Panel Block
Repair System Description: Same
Maintenance Agreement Required: ☒ Yes ☐ No

☒ House/Mod. Home No. Bedrooms 4
☐ Mobile Home No. Persons
☐ Business No. Employees
☐ Other

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions: Note: Use trench width as specified in plan submitted by Rollans Soil & Environmental.

Comments:/Conditions: 4/14/08 Reviewed Floor plans in Compliance with original permit. Okay to change line lengths may be 70, 100, 45 & 100
8/22/08 Checked tanks Installed LP-Panel Blk lines Set 3Ft pressure head Electric alarm set 9/8/08

INITIAL SITE SKETCH

See Approved plan (attached) by Rollans Soil & Environmental Services

AS BUILT SKETCH

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: L Edward Berry date

Improvement Permit by: Maria H Dotson date 9/17/07

Authorization to Construct by: Maria H Dotson date 4/14/08

Installed by: Larry Beane

Operation Permit by: Maria H Dotson date 9/9/08

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK