12:00

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 140297 PIN# 4679318736.008 4629 St 1212 DATE 6-15-07

OWNER OR APPLICANT T+E Developers LLC PHONE: Business 704-202-9595 Home

ADDRESS 112 Vista Bluff Ln Mooresville NC 28117

LOCATION Main St N (152) cross 150 to Wiggins Th Kerri Ln on left

SUBDIVISION Kerri Plantation BLOCK / SECTION LOT 8 LOT AREA 1.01 Ac SITE CLASS. PS DESIGN FLOW 480 gpd L.T.A.R. .3 gpd/ft²

Septic Tank: 1000 Gallons; STB 1012 Date 6-6-08

Pump Tank: Gallons; PT Date

Pump Make: Model Serial No.

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400

No Lines 3 Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I (II) III IV V VI

System Description: 25 90 reduction gravity

Repair System Description: LP PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No

Gravel Depth NA ☒ Gravity ☐ Pressure

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons 8 No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

Comments:/Conditions:

Place well 100' from system

Comments:/Conditions:

INITIAL SITE SKETCH

See Plan from Rollans Soil & Environmental Services Inc

AS BUILT SKETCH

Installed Essentially as Drawn Used Quick 4

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☒ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Julie A Smith date 6/27/07 Installed by: Bunter Gradinars

Improvement Permit by: Judy Melville date

Authorization to Construct by: Wesley Sparks RS date 8/11/09 Operation Permit by: Maria Dotson date 11/30/09

Existing System Inspection by: date

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK