Lot 6
1.31 Ac.
326.4
60'
95' Setback
60'
360.1
Lot 7
1.01 Ac.
247.4
N89°12'57"W
240.9
Lot 8
1.04 Ac.
DRIVE
85.5
WELL
60'
60'
TBM 1.5'
CVB
8.2' 80'
9.2' 80'
1 5.1 DP 35'
2 6.2 B 50'
3 7.1 P 60'
4 8.2 DP 75'
5 9.3 B 50'
6 10.4 P 104'
7 11.2 O 120'
8 10.3 DP 120'
DP 120'

for ON-SITE WASTEWATER SYSTEM

OWNER: T & E DEVELOPERS APPLICATION DATE 2/07
ADDRESS: 112 VISTA BLUFF MOORESVILLE, NC 28117 DATE EVALUATED: 2/07
PROPOSED FACILITY: RES PROPOSED DESIGN FLOW (.1949): 480 PROPERTY SIZE:
LOCATION OF SITE: KERRI PLANTATION LOT 7 PROPERTY RECORDED: Y
WATER SUPPLY: X Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: X Auger Boring X Pit ☐ Cut TYPE OF WASTEWATER: X Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
7A 1	LSS/CC 5-10%	0-21	RC mfsm	fri sssPsp					PS .3
		21-28	RCL wfsm	fri sssPsp					
		28-60	VFSLPM	fri sssPsp	-	28	PS	-	
7B 2		0-6	BSCL MC	fri sssPsp					PS .3
		6-30	RC SM	fri sssPsp					
		30-48	RCL WSM	fri sssPsp	-	48	-	-	
P57 3		0-12	RC SM	fri sssPsp					PS .3
		12-28	RCL WSM	fri sssPsp					
		28-58	SLSAPM	fri NSNPNP	-	28	PS	-	
P58 4	↓	0-12	RCL WSM	fri sssPsp					PS .3
		12-58	SLSAPM	fri sssPsp	-	12"	PS	-	

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	PPBPS	PPBPS
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Rollins Soil & Environmental Services
OTHER(S) PRESENT: LARRY BEAM, ADRIAN PRUETT

COMMENTS:

Lot 6
1.31 Ac.
Lot 7
1.01 Ac.
Lot 8
1.04 Ac.
326.4
360.1
247.4
240.9
N89°12'57"W
TBM 1.5
CVB
DRIVE
WELL
95' Setback
60'
Blue St.
Future Boat storage
Old Site Notes Berm