DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ___ OF ___
PROPERTY I.D.#: 4H 2A5
PROPERTY RECORDED: ___
COUNTY: ___

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Ellen Oliphant OWNER: ✓ AGENT: ___ PHONE: ___
ADDRESS: Confederate Rd. APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___
PROPERTY SIZE: ~ 4 Ac
LOCATION OF SITE: ___
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS	HORIZON LTAR
1		0-11	VF SBK CL	1:1/S SP	D				
		12-23	wk SBK SiC	1:1/F S SP					
		24-39	SBK C	1:1/S P SFI					
		40-	wk SBK CTRAN	1:1/S P FI					
2									
3									
4									
5									

AVAILABLE SPACE (.1945) S SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE .25-.3
EVALUATED BY: Sparks OTHER(S) PRESENT: ___
COMMENTS: ___