IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 140293 PIN# 4679318736.003 4679410749

OWNER OR APPLICANT T & E Developers LLC PHONE: Business 704 902-9595 Home

ADDRESS 112 Vista Bluff Ln Mooresville, NC 28117 DATE 3-5-07

LOCATION Hwy 801 North TR Wiggins Rd TR Kerri Ln on left Savannah Crossing

SUBDIVISION Kerri Plantation BLOCK / SECTION LOT 3 LOT AREA 1.02 Acre SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .3

Y2-HP

Septic Tank: 1000 Gallons: STB 338 Date 4-16-07

Pump Tank: 1000 Gallons: PT 27 Date 3-6-07

Pump Make: Goulds Model WE0512HP10 Duplex

Nitrification Field: No Fields 1 Square Feet 1200 Linear Feet 400'

No Lines 5@80' Trench Width 36" Max Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II III IV V VI

System Description: Pump- 25% Reduction

Repair System Description: LPP PBPS

Maintenance Agreement Required: ☐ Yes ☐ No

☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons No. Employees

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments/Conditions: Site evaluated & layout performed by Rollans Soil & Environmental Services.

★ Okay to switch tank's location

Comments/Conditions: 12/07 Reviewed floor plans, essentially in compliance with original plan. 9/4/07 Installed in 4-100' lines is ok

INITIAL SITE SKETCH

★ See approved plan by Rollans Soil & Environmental Services

AS BUILT SKETCH

90ft btw well & tanks

25 chambers per ditch 9/6/07

Installed 4-100ft Quick 4

Pl 283'

Repair Area

51'

Drive

House

Some Repair

Pl 290

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed: Melissa Snead

Improvement Permit by: Melissa H Dolan RS date 4/10/07 Installed by: Larry Beam

Authorization to Construct by: Melissa H Dolan RS date 3/5/07 Operation Permit by: Melissa H Dolan RS

date 4/26/07 Existing System Inspection by: date 10/11/07

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK

date