5.00 David Martin 315

IREDELL COUNTY HEALTH DEPARTMENT

STATESVILLE 704-878-5305 MOORESVILLE 704-664-5281

IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM INSPECTION

PERMIT# 40291 PIN# ~~4679431872~~ 4679410932 DATE 3-5-07

OWNER OR APPLICANT T & E Developers LLC PHONE: Business 202-9595 Home

ADDRESS 112 Vista Bluff Ln Mooresville, NC 28117

LOCATION Hwy 801 N TR Wiggins Rd TR Kerri Ln on left Savannah Crossing on left

SUBDIVISION Kerri Plantation BLOCK / SECTION LOT 2 LOT AREA 1.06 Acre SITE CLASS PS DESIGN FLOW 480gpd L.T.A.R. .275

Septic Tank: 1000 Gallons: STB 1012 Date ~~2-23-07~~ 2-27-07

Pump Tank: 1000 Gallons: PT 17 Date 5-5-09

Pump Make: Goulds Model PES1M Serial No. 1/2 HP

Nitrification Field: No Fields 1 Square Feet 1305 Linear Feet 435'

No Lines 3@145' Trench Width 36" Max Trench Bottom Depth 36"

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: Pump-PM-25% Reduction

Repair System Description: LP-PPBPS

Maintenance Agreement Required: ☐ Yes ☒ No Not Initially

Gravel Depth N/A ☐ Gravity ☒ Pressure ☐ Slab ☒ Crawl Space ☐ Basement w/plumbing ☐ Basement wo/plumbing

☒ House/Mod. Home ☐ Mobile Home ☐ Business ☐ Other

No. Bedrooms 4 No. Persons ___ No. Employees ___

Water Supply: ☒ Individual ☐ Public ☐ Community

Comments/Conditions: Site evaluated & layout performed by Rollans Soil & Environmental Services 5/15/2012 Checked Tanks & lines ★★

Comments/Conditions: 2/7/2011 Reviewed Floor plans in Compliance with original plans. ★Must build house as shown on original Plan by Rollans Soil & Env. Services dated 2/21/07

INITIAL SITE SKETCH

★ See approved plan by Rollans Soil & Environmental Services.

AS BUILT SKETCH

Used Quick 4

Installed Drainfield essentially as Drawn

Tank location revised 100ft from well

Permit can be suspended or revoked if any false information is supplied toward securing the permit/any unauthorized changes are made to the site/any unauthorized changes are made in the installation of the system. Improvement Permit with plat valid without expiration ☐ Improvement Permit with site plan valid for sixty months ☐ Authorization to Construct is valid for a period equal to that of Improvement Permit – not to exceed sixty months.

Signed Julie M Smith date 4/10/07 Installed by: Gunter Grading

Improvement Permit by: Maria H Nelson RS date 3/5/07 Operation Permit by: K. Alley REHS date 6-18-12

Authorization to Construct by: Maria H Nelson RS date 2/7/12 Existing System Inspection by: ___ date ___

HEALTH DEPT. COPY: WHITE OWNER COPY (FINAL): YELLOW OWNER COPY (INITIAL): PINK