DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ❑ Private ❑ Public ❑ Well ❑ Spring ❑ Other _____
EVALUATION METHOD: ❑ Auger Boring ❑ Pit ❑ Cut
TYPE OF WASTEWATER: ❑ Sewage ❑ Industrial Process ❑ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	SS	0 - 9	GR SCl	FR SS NP					
		10 - 16	GR LSCl	FR SS NP					
		17 - 25	wk sbk Cl	FR SS SP					
		26 -	wk sbk HCl	FI S P	water now in —				
2	SS	0 - 8	wk GR Cl	FR SS SP (SEXP)					
		9 - 20	sbk hCl	FI S P					
		21 - 32	wk sbk Cl	FR SS SP					
		33 - 47	Bg Cl	VFR NS NP (SEXP)					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____

DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: True Gospel Bapt. Church
ADDRESS: ___
APPLICANT: Rodney McCallister
APPLICATION DATE: ___
PROPOSED FACILITY: ___
PROPOSED DESIGN FLOW (.1949): 1000GPD
DATE EVALUATED: 12/3/96
LOCATION OF SITE: Wiggins Rd (R) off 801 N ~ to Irwin
PROPERTY SIZE: ~5.00 AC
PROPERTY RECORDED: ___
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other 5GP.D DWE T. KITCHEN
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR. HORIZ.	PROFILE CLASS & LTAR
1	T 2%	0-5	sbk / hcl dk BR.	FI S P					
		6-18	sbk / hcl R	F S P					
		19-46	sg / cl	FR S SP					
2	T	0-8	dk sbk / cl	FR S P					
		9-18	R wk sbk / hcl	FI S P					
		19-26	GR / mcl	FR SS SP					
		27-45	GR / cl	VFR NS NP.					
Below Chuck 3	E T	0-7	dk sbk / cl	FR SS SP					
		8-24	R wk sbk / mic cl	FR SS SP					
		25-36	sbk / c	FI SS SP					
		37 ~	mic wk sbk / cl	FR SS NP			7 S		.23-.8
Terrace Edge 4		0-8							
		8-44							
		45						U	

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: ___
OTHER(S) PRESENT: ___