4679433201

10902

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W. E. Smith DATE April 11, 1990 PERMIT NO. 4C-A-28

PHONE: Business _____ Home _____

LOCATION 801 N. On right just before junction with 2399 Wiggins Rd. S. R. No. _____

SUBDIVISION NAME Smith Property LOT NO. 9 SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site ~~Suitable~~ PS	Yes (✓)	No ( )	

Lot Area 40,000 ft² 200'x200'

Character & Porosity of Soil PS clay


Percolation Rate No. 4

Topography 2-4% D

Depth to Water Table 4'+

Rock or other impervious formations none obs.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 900 Linear Ft. 300'

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

80' Neighbor's Well

Installed by Terry Smith

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Sam Ingram EHS DATE April 11, 1990

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold