DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Keith Carroll
ADDRESS: 165 French Bulk Rd Mt Ulla APPLICATION DATE: ____ DATE EVALUATED: 3/21/96
APPLICANT: Same
PROPOSED FACILITY: 3BR PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .904
LOCATION OF SITE: Coal Creek Rd - Twin Brooks Lot #11 PROPERTY RECORDED: ~~Book~~ 33
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	3%	0-6	SCL GR	FRI SS SP					.3 PS
		6-24	C SBK	FI SP					
		24-48	CL WSBK	FRI SS SP					
2	3%	0-8	SCL GR	FRI					.3 PS
		8-26	C SBK	FI					
		26-48	CL WSBK	FRI					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	~~900~~ 900	900
System Type(s)	Chambered	Same
Site LTAR	.3	.3

OTHER FACTORS (.1946):
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: C. Brady Freeman
OTHER(S) PRESENT: Keith Carroll