IREDELL COUNTY HEALTH DEPARTMENT 4079528384

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Grady A. Atwell DATE 6-14-85 PERMIT NO. 268

PHONE: Business _____ Home _____

LOCATION 801 E TR 2401 (Sloop Road) ½ mile on R

S. R. No. _____

SUBDIVISION NAME Bill Edmonston prop. LOT NO. 10 SECTION OR BLOCK NO. _____

House (X) Mobile Home ( ) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (X)	
Auto. Dishwasher	Yes (X)	No ( )	
Auto. Wash. Machine	Yes (X)	No ( )	
Site Suitable	Yes (X)	No ( )	

Lot Area 2.69 Acres

Character & Porosity of Soil Clay Hardpan
Percolation Rate 25 gpd
Topography Rolling
Depth to Water Table 4+
Rock or other impervious formations None 065

_____ Basement with Plumbing _____ Basement without Plumbing X No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 720 Linear Ft. 240
Depth of Stone in Lines 12"

Water Supply: Individual (X)
Public ( )

Installed by Larry Boone

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. Clemmer

COMMENTS: OK Agent Change

CERTIFICATE OF COMPLETION BY Jack Clemmer DATE 6-14-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold