4679531326

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenny Davis DATE 2/14/89 PERMIT NO. PC

PHONE: Business _____ Home 663-0215

LOCATION 801 N. of Mooresville TR Shoop Rd. ~ 1/8 mi. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

Tax#4C-A-52

House (✓) Mobile Home ( ) Business ( ) Other * Second Creek watershed


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Clay (Shallow)
Percolation Rate .35 gpd/ft²
Topography 60%
Depth to Water Table 4'+
Rock or other impervious formations none obs.

Lot Area 3.45 Acre

___ Basement with Plumbing ___ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by Larry Beam

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY ACP

COMMENTS: _____

CERTIFICATE OF COMPLETION BY André C. Pierce DATE 2/14/89

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

09017

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Kenny Davis DATE 9/19/88 PERMIT NO. 19C

PHONE: Business _____ Home 663-0215

LOCATION 801 N of Mooresville. TR Sloop Rd. ~ 1/8 mile on R. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

TAX#: 4C - A - 52 BARRINGER


House (✓) Mobile Home ( ) Business ( ) Other *Second Creek Watershed

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clayey (SHALLOW)
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	.35 gpd/ft2
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	60%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'+
			Rock or other impervious formations	none observed

Lot Area 3.45 Ace

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System NOT TO SCALE

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 1035 Linear Ft. 345
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X Kenny Davis

IMPROVEMENTS PERMIT BY André C. Pierce

COMMENTS: Install system SHALLOW (24" max trench depth) Should have 12" natural cover over entire drainfield line. Therefore, drainlines must run on contour. (*) Plumbing will have to brought out just below ground level in order to meet these guidelines.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold