IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herb Nabb DATE 4-18-75 PERMIT NO. 44

PHONE: Business _____ Home 932-2435

LOCATION 1146 TL on 1143 TR on 1144 Rustic Rd. 1/2 mi on left on Patterson Farm Rd./Juniper Rd. S. R. No. 1144

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 4 ✓

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 3.7 acres

Character & Porosity of Soil Clay loam Parent Rock
Percolation Rate Not taken
Topography 2% Slope
Depth to Water Table 4'+
Rock or other impervious formations None



Plot of System

Size of Tank 1800 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 800 Linear Ft. 250
Depth of Stone in Lines 24" to 30"
Water Supply: Individual Well
Public (Co.)
Other

Installed by The Sanitarian
Kannapolis, N.C.

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: lines were going in where grade of land was dropping therefore stopped at 125' + added P.I. at end. Had much more stone than was required

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 4-19-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

Cr ... 50' ... Harris

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herb Nabb DATE 2-27-75 PERMIT NO. 32

PHONE: Business _____ Home 932-2435

LOCATION 1146 T L on 1143 T Rt on 1144 ½ mi on Left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2½

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Lot Area 3 Acre

Character & Porosity of Soil Clay Loam Poros. & Fair
Percolation Rate 1" per Taken
Topography 2% Slope
Depth to Water Table 10'
Rock or other impervious formations None



Plot of System

Size of Tank 1500 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 18"
Water Supply: Individual (✓)
Public ( )

Installed by _____

Grade area were Lines to be to make Level Cover on Nitrification Line

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: Set Tank below Basement Level 3' Fall 270' to Nitrification Line 12" of Stone below Pipe on 4" to Top of Pipe on Line from Tank to Line Put Cleanout Every 50'

CERTIFICATE OF COMPLETION BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold