1144 = Rustic Rd. ✓ 4684-18-3698.000

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Herb Nabb DATE 4-18-75 PERMIT NO. 77

PHONE: Business _____ Home 932-2435

LOCATION 1146 TL on 1143 TR on 1144 1/2 mi TL on left S.R. No. 1144

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 4 ✓

Garbage Disposal Unit	Yes ( )	No	(✓)
Auto. Dishwasher	Yes (✓)	No	( )
Auto. Wash. Machine	Yes (✓)	No	( )
Site Suitable	Yes (✓)	No	( )

Lot Area 37 acres

Character & Porosity of Soil Clay loam Percolation Rate Not taken Topography 2% slope Depth to Water Table 10' + Rock or other impervious formations None



Plot of System

Size of Tank 1800 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 500 Linear Ft. 250
Depth of Stone in Lines _____
Water Supply: Individual Well

Installed by [illegible] Kannapolis, N.C.

IMPROVEMENTS PERMIT BY John Houston

COMMENTS: lines were going in where grade of land was dropping therefore stopped at 125' + added 12' PVC at end. Has much more stone than was required.

CERTIFICATE OF COMPLETION BY J. C. Monk DATE 4-18-75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold