DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Terry Welcher APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 1/21/2000
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: Patterson Farm Rd PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1		0-10	Brn SCL/CL w SBK	SS,SP,SE FR					PS .3
		10-32	Rd/Brn C/CL m-w SBK	SS,SP,SE FR					
		32-40	Rd/Brn CL w SBK	SS,SP,SE FR					
			(Deeper Soils looked better)						
2		0-10	Brn SCL/CL w SBK	SS,SP,SE FR					PS .2-.25
		10-40	Brn C m SBK	SP,SE,FI-FR					
		40-48	Brn C/CL m-w SBK	SS,SP,SE,FI-FR					
3		0-10	Brn SCL/CL w SBK	SS,SP,SE FR					PS .25-.3
		10-36	Brn C m SBK	SP,SE,FI-FR					
		36-48	Brn C/CL m-w SBK	SS,SP,SE FR					
			*Soil Gets better the further uphill you go.						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)		
System Type(s)		
Site LTAR		

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): _____
EVALUATED BY: _____
OTHER(S) PRESENT: _____