CONCRETE SUPPLY

CONCRETE SUPPLY CO.

READY-MIXED CONCRETE

4 March 1999

Mr. Kent Curlee
Curlee's Pre-Cast Tanks
26009 Mulberry Road
Albemarle, NC 28001

Dear Mr. Curlee:

On February 3,1999 Mr. Andy Cirulis made a set of 6 test cylinders at your plant. Mr. Cirulis is employed as a Senior Lab Technician at Concrete Supply Co., and is NCDOT and ACI certified. The cylinders were cast from your 3500 psi mix. The results are as follows.

7 days	3750	
14 days	4105	4295
28 days	4775	4795

If we may be of further service please advise.

Sincerely,

J. A. Hopkins

Lead Lab Technician